



April 19, 2024

**Addendum No. 1
BL047-24
Ridgedale Way Water Main Replacement**

The following addition/changes modify the Bid No. BL047-24 "Ridgedale Way Water Main Replacement Contract Documents, dated April 2024, as first advertised on April 03, 2024.

I. Questions:

Q1. What method of installation will be used? Is it open cut or will there be any boring involve? Jack and Bore or Directional Bore?

A1. Installation of the water main shall be mostly done by open-cut method. All concrete and/ or Asphalt driveways are to be free-bored unless noted otherwise in the bid drawings.

Q2. What are the approximate lengths and diameters of the portions to be bored?

A2. Refer to bid drawings for lengths and diameters of the portions to be free-bored.

Q3. What is the cost estimate for this project?

A3. There is approved funding for this project. Gwinnett County expects each contractor to bid a competitive price. The award will be made to the lowest responsive and responsible bidder.

Q4. Please provide a plan holders list.

A4. Please see attachment A1.

II. Attachment:

A1. Plan holders list as of 04/18/2024.

All bidders shall acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject the bidder to disqualification. This addendum forms a part of the Contract Documents.

Sincerely,

Brittany Bryant, CPPB

Purchasing Associate III

BL047-24 RIDGEDALE WAY WATER MAIN REPLACEMENT**PLAN HOLDERS LIST AS OF 4/18/2024**

#	Company Name	Company Type	Address	Contact	Email	Phone
1	Site Engineering Inc	General Contractor	7025 Best Friend Road Atlanta, GA 30340	Tamara L Isbell	tamara@siteengineeringinc.com	Phone: 770-263-7234 ext. 228 Mobile: 678-315-1051
2	Civil Construction & Utilities, LLC	General Contractor	PO Box 902 Jefferson, GA 30549	Scott King	jason@cc-u.net; scott@cc-u.net	770 842-4342 office 770 377-1438 cell
3	F.S. Scarbrough, LLC	General Contractor	P.O. Box 2613 Peachtree City, GA 30269	Erika Adams	eadams@fsscاربrough.com	678.621.9888